

From: "Plummer, Ted" <Ted.Plummer@syd.com.au>
To: "Chris King" <Chris.King@planning.nsw.gov.au>
CC: "Bleasdale, Peter" <peter.bleasdale@syd.com.au>
Date: 1/29/2013 11:07 am
Subject: RE: Preferred Project Report for the Rozelle Village/Balmain Leagues Development Off Victoria Road (MP_110015)

Hi Chris

The fact the building no longer penetrates the airspace protection surfaces does resolve the issue we raised in the original 2012 letter. However, as cranes would still penetrate these surfaces, Commonwealth approval would still be required for the construction work to commence.

cheers

Ted Plummer

Manager Government and Community Relations

Sydney Airport Corporation Limited

Tel: +61 2 9667 6182

Mob: +61 409 072 436

Ted.Plummer@syd.com.au

www.sydneyairport.com.au