

WSP Buildings Pty Ltd
ABN 47 005 113 468

Level 1 41 McLaren Street
PO Box 6245 North Sydney
New South Wales 2060 Australia

T. 61 2 8907 0900
F. 61 2 9957 4127

sydney@wspgroup.com.au
wspgroup.com.au

1122100-PA memo Form Revision: 1.01/07

To	Frasers Property	Date	25 September 2012
Attention	Anthony Green	Email	anthony.green@frasersproperty.com.au
From	Dedman, Ben	Project No	SYD1122100
Project	Kensington St Precinct, Blocks 3B, 3C and 10	No. of pages	1
Subject	Project Application	Copies	

Anthony,

With reference to the project application for Kensington Street Precinct student accommodation and the WSP project application report dated 12th April 2012, we can confirm that the solution for ventilation to the kitchenettes within the student apartments will include mechanical ventilation via a hood above the cooking range. This will either be a recirculating hood with filter or extract hood exhausting to atmosphere.

Each unit will also include mechanical extract from the bathrooms as described within section 2 of the PA report.

Regards

Dedman, Ben
Associate Director

This document may contain confidential and legally privileged information, neither of which are intended to be waived, and must be used only for its intended purpose. Any unauthorised copying, dissemination or use in any form or by any means other than by the addressee, is strictly prohibited. If you have received this document in error or by any means other than as authorised addressee, please notify us immediately and we will arrange for its return to us.