



DOC20/491820

23 June 2020

Ms Megan Fu
Senior Planning Officer
Social Infrastructure and Other Assessments
Department of Planning, Industry and Environment
GPO Box 39
Sydney NSW 2001

Dear Ms Fu

**Liverpool Hospital Multi-Storey Carpark (SSD 10388)
Advice on the Environmental Impact Statement (EIS)**

I am writing to you in reply to the invitation to the Environment Protection Authority (EPA) to provide advice on the Environmental Impact Statement (EIS) for the above proposal.

The EPA understands that the project involves the construction and operation of a seven-level carpark involving demolition works; remediation works; road connections and landscaping.

The EPA has reviewed the EIS provided by the Department of Planning, Industry and Environment (DPIE) and provides advice regarding noise and vibration and contaminated lands in Appendix A.

Should you require clarification of any of the above please contact Anna Timbrell on 9274 6345 or email anna.timbrell@epa.nsw.gov.au

Yours sincerely

A handwritten signature in black ink, appearing to read 'B. Treharne'.

BENN TREHARNE
A/Unit Head, Regulatory Operations – Metro South
Environment Protection Authority

Phone 131 555
Phone 02 9995 5555
(from outside NSW)

Fax 02 9995 6900
TTY 133 677, then
ask for 131 155

PO Box 668
PARRAMATTA
NSW 2124

4 Parramatta Square
12 Darcy Street
PARRAMATTA NSW
2150 AUSTRALIA

info@epa.nsw.gov.au
www.epa.nsw.gov.au
ABN 43 692 285 758

APPENDIX A

1. Noise

The EPA reviewed the document *Redevelopment of Multi-Storey Carpark*, dated 07.05.20, prepared by Acoustic Logic (acoustic report) and has considered both construction and operational noise matters as follows:

Construction Noise Assessment

The EPA considers additional information must be provided regarding:

- the application of a 5 dB penalty to the sound power level of some construction equipment;
- an assessment of the cumulative impact of plant and equipment for construction scenarios;
- more assessment of the application of mitigation measures for specific construction scenarios; and
- justification for out of standard hours work in accordance with the *Interim Construction Noise Guideline* (DEC, 2009) (ICNG).

The acoustic report lists in Table 27 the sound power levels for items of construction plant and equipment proposed to be used during construction activities for the project. It is noted that two of these items (a handheld jackhammer and powered hand tools) have been labelled as attracting a 5 dB penalty due to their annoying noise characteristics. The EPA considers that other items in Table 27, such as the excavator with hydraulic hammer, vibratory roller and demolition saw, would also be likely to attract a 5 dB penalty due to annoying characteristics, however have not been marked as such in the table. The applicant should review the sound power levels in Table 27 and whether any additional penalties are applicable.

The applicant should also provide an assessment of the predicted impacts from the proposed construction activity scenarios (e.g. demolition of existing structures, foundation excavation, piling, construction of new building, etc.) which will comprise the use of a number of the plant and equipment items concurrently, as well as predicted noise impacts for individual plant items.

The EPA notes that significant noise impacts are predicted from the proposed construction activities both during standard construction hours and outside standard construction hours, in some cases approaching the 'highly noise affected' level in the ICNG. The acoustic report makes a range of general recommendations for mitigation measures that could be employed to reduce noise from construction activities. However, no specific assessment of how these measures could be applied to the equipment list of Table 27 and the resultant reductions in overall impacts at sensitive receivers for the various construction activity scenarios has been provided.

The acoustic report has put forward a very brief justification for adopting construction hours outside the standard hours in Sections 10.1 and 12.1. Proposed hours are:

- Friday – 6:00 pm to 10:00 pm period
- Saturday – 1:00 pm to 3:00 pm
- Saturday – 5:00 pm to 10:00 pm;
- Sunday – 8:00 am to 5:00 pm; and
- Sunday – 5:00 pm to 10:00 pm

Based on the information provided the EPA does not have sufficient information to support the out of hours construction activity, including the need for: 1) detailed justification (refer section 2.3 of the ICNG); 2) details of construction scenarios; and 3) appropriate mitigation measures being put forward to reduce noise impacts to an acceptable levels.

Operational Noise Assessment

The acoustic report has set noise criteria for operational noise emissions from mechanical plant and equipment from the proposal in Sections 5.4. Section 6.3 discusses the generic operational mechanical noise sources likely to be installed on site, together with a broad description of whether they will be able to satisfy the operational noise criteria, and what mitigation measures may be required to address these noise emissions. However, detailed and specific assessment and discussion on these matters has not been included in the acoustic report and has been deferred to the post-consent detailed design stage.

The EPA recognises the staged nature of the design process in significant projects such as these, and that limited detail may be available on which to base a comprehensive assessment of operational noise in the early stages of this process. However, the SEARs for the project clearly require that the applicant 'identify and provide a quantitative assessment of the potential noise and vibration impacts on the identified sensitive receivers due to the operations of the hospital'.

A more detailed quantitative assessment of the potential operational noise impacts from the proposal – using representative items of plant and equipment referenced from similar projects or other suitable sources – should be provided to satisfy the SEARs requirement. This should include a quantitative assessment of the effectiveness of any feasible and reasonable noise mitigation and management measures, should they be required, to achieve the noise criteria put forward in the acoustic report. In lieu of this, specifying target operational noise design criteria is an appropriate alternative.

Unless additional assessment is undertaken, the EPA recommends the following conditions of consent for construction and operational noise and vibration.

Construction Noise Conditions

Hours of Construction

L6.11 All construction work at the premises must be conducted between 7am and 6pm Monday to Friday and between 8am and 1pm Saturdays and at no time on Sundays and public holidays, unless inaudible at any residential premises.

Exceptions to construction hours

The following activities may be carried out outside the recommended construction hours:

- a) construction that causes $L_{Aeq(15\text{minute})}$ noise levels that are:
 - i. no more than 5dB above Rating Background Level at any residence in accordance with the *Interim Construction Noise Guideline* (DECC, 2009); and
 - ii. no more than the Noise Management Levels specified in Table 3 of the *Interim Construction Noise Guideline* (DECC, 2009) at other sensitive land uses; or
- b) for the delivery of materials required by the police or other authorities for safety reasons; or
- c) where it is required in an emergency to avoid the loss of lives, property and/or to prevent environmental harm; or
- d) as approved through the process outlined in "Variation of construction hours" of this consent.

Variation of construction hours

The hours of construction activities specified under "Exceptions to construction hours" d) of this consent may be varied with the prior written approval of the Secretary. Any request to alter the hours of construction shall be:

- a) considered on a case-by-case or activity-specific basis
- b) accompanied by details of the nature and justification for activities to be conducted during the varied construction hours
- c) accompanied by written evidence that appropriate consultation with potentially affected sensitive receivers and notification of relevant Council(s) (and other relevant agencies) has been and will be undertaken
- d) all feasible and reasonable noise mitigation measures have been put in place
- e) accompanied by a noise impact assessment consistent with the requirements of the *Interim Construction Noise Guideline* (DECCW, 2009).

Operational Noise Conditions

L6.1 Noise generated at the premises must not exceed the noise limits at the times and locations in the table below. The locations referred to in the table below are indicated by Liverpool Health and Academic Precinct Redevelopment of Multi-Storey Carpark (SSD:10388) Acoustic Assessment Report prepared by Acoustic Logic (Ref 20181547.2 Rev 6 dated 7 May 2020).

| Location | Noise Limits in dB(A) | | | |
|---------------|------------------------------|------------------------------|------------------------------|--------------------|
| | Day | Evening | Night | Night |
| | L _{Aeq} (15 minute) | L _{Aeq} (15 minute) | L _{Aeq} (15 minute) | L _{AFmax} |
| Any residence | 47 | 43 | 38 | 54 |

L6.2 For the purposes of condition L6.1:

- Day means the period from 7am to 6pm Monday to Saturday and the period from 8am to 6pm Sunday and public holidays.
- Evening means the period from 6pm to 10pm.
- Night means the period from 10pm to 7am Monday to Saturday and the period from 10pm to 8am Sunday and public holidays.

L6.3 - Standard Meteorological Conditions

- a) The noise limits set out in condition L6.1 apply under the following meteorological conditions:

| Assessment Period | Meteorological Conditions |
|-------------------|--|
| Day | Stability Categories A, B, C and D with wind speeds up to and including 0.5m/s at 10m above ground level |
| Evening | Stability Categories A, B, C and D with wind speeds up to and including 0.5m/s at 10m above ground level |
| Night | Stability Categories A, B, C and D with wind speeds up to and including 0.5m/s at 10m above ground level |

- b) For those meteorological conditions not referred to in condition L6.3(a), the noise limits that apply are the noise limits in condition L6.1 plus 5dB.

L6.4 For the purposes of condition L6.3:

- The meteorological conditions are to be determined from meteorological data obtained from the meteorological weather station identified as **Bureau of Meteorology AWS at Bankstown Airport**
- Stability category shall be determined using the following method from Fact Sheet D of the *Noise Policy for Industry* (NSW EPA, 2017):
 - Use of sigma-theta data (section D1.4).

L6.5 To assess compliance:

- a) with the $L_{Aeq(15 \text{ minutes})}$ or the L_{Amax} noise limits in condition L6.1 and L6.3, the noise measurement equipment must be located:
 - (i) approximately on the property boundary, where any residence is situated 30 metres or less from the property boundary closest to premises; or where applicable,
 - (ii) in an area within 30 metres of a residence façade, but not closer than 3 metres where any residence on the property is situated more than 30 metres from the property boundary closest to the premises; or, where applicable,
 - (iii) in an area within 50 metres of the boundary of a National Park or Nature Reserve,
 - (iv) at any other location identified in condition L6.1
- b) with the $L_{Aeq(15 \text{ minutes})}$ or the L_{Amax} noise limits in condition L6.1 and L6.3, the noise measurement equipment must be located:
 - (i) at the reasonably most affected point at a location where there is no residence at the location; or,
 - (ii) at the reasonably most affected point within an area at a location prescribed by condition L6.5 (a).

L6.6 A non-compliance of conditions L6.1 and L6.3 will still occur where noise generated from the premises is measured in excess of the noise limit at a point other than the reasonably most affected point at the locations referred to in condition L6.5 (a) or L6.5 (b).

NOTE to L6.5 and L6.6: The reasonably most affected point is a point at a location or within an area at a location experiencing or expected to experience the highest sound pressure level from the premises.

L6.7 For the purpose of determining the noise generated from the premises, the modifying factor corrections in Table C1 in Fact Sheet C of the *Noise Policy for Industry* (NSW EPA, 2017) may be applied, if appropriate, to the noise measurements by the noise monitoring equipment.

L6.8 Noise measurements must not be undertaken where rain or wind speed at microphone level will affect the acquisition of valid measurements.

Other Conditions

The EPA recommends that any consent for the project includes conditions requiring:

- A compliance tracking program and reporting, to monitor compliance with the conditions of consent;
- An environmental auditing program and reporting, to assess compliance of the project with the conditions of consent;
- A requirement to notify incidents to the Department of Planning and Environment, in addition to the EPA's notification requirements;
- Preparation and implementation of a community communication strategy;
- Preparation and implementation of a complaints management system;
- An independent community complaints commissioner to follow up on complaints not resolved by the applicant to the complainant's satisfaction;
- Preparation and implementation of a construction environmental management plan detailing how performance outcomes, commitments and mitigation measures will be implemented;
- Preparation and implementation of a noise and vibration sub-plan, in consultation with relevant authorities;
- Construction noise and vibration impact statements for each construction site, specifying mitigation measures identified through consultation with affected noise sensitive receivers;
- An out-of-hours works protocol;
- Implementation of the applicant's construction noise and vibration strategy; and
- Construction noise and vibration monitoring programs.

2. Contaminated Lands

Three technical appendices were provided as part of the EIS regarding contamination at the site: *Stage 2 Environmental Site Assessment*, dated 29.01.20, prepared by JK Environments (site assessment report); *Hazardous Building Materials Survey for Proposed Demolition Works*, dated 05.09.19, prepared by JK Environments; and *Remediation Action Plan*, dated 29.04.20, prepared by JK Environments (RAP).

The site assessment report identified potential contaminants sources / areas of environment concern resulting from: imported fill materials; historical agricultural use; hazardous building materials (demolition activities), and; former on-site and off-site fuel storage, mechanical workshop, dry cleaning and printing in the area. Petroleum hydrocarbons in some soil samples exceeded the adopted criteria.

The site assessment report found that the risk to human and ecological receptors is low and the site can be made suitable for the proposed development if the following recommendations are implemented:

- additional asbestos assessment is undertaken following demolition of the existing multi-storey carpark to address the data gap;
- the Remediation Action Plan (RAP) is updated based on the results of the additional asbestos assessment;
- an Acid Sulfate Soil Management Plan (ASSMP) is prepared;
- a Salinity Management Plan (SMP) is prepared; and
- a Construction Environmental Management Plan (CEMP) is prepared to include an unexpected finds procedure for contamination.

An ASSMP was provided as appendix N3 and the RAP as appendix N2. The RAP included a methodology for further assessment to close the data gap in areas of environmental concern in the western part of the site; methodology to remediate and validate; management procedures during remediation work; and an unexpected finds protocol.

The EPA recommends the following conditions of consent:

1. The applicant must conduct a **Detailed Site Investigation** to determine the full nature and extent of the contamination at the project area after demolition works. The **detailed site investigation(s)** must be undertaken, and the subsequent report(s), must be prepared in accordance with relevant guidelines made or approved by the EPA under section 105 of the *Contaminated Land Management Act 1997*. The reports must be prepared, or reviewed and approved, by consultants certified under either the Environment Institute of Australia and New Zealand's Certified Environmental Practitioner (Site Contamination) scheme (CEnvP(SC)) or the Soil Science Australia Certified Professional Soil Scientist Contaminated Site Assessment and Management (CPSS CSAM) scheme.
2. The **Unexpected Finds Procedure** and the **Remediation Action Plan (RAP)** must be updated following results of further detailed site investigations and implemented throughout duration of project work.
3. Prior to commencement of operation, the applicant must submit a **Validation Report** for the development. The **Validation Report** must:
 - a) be prepared, or reviewed and approved, by consultants certified under either the Environment Institute of Australia and New Zealand's Certified Environmental Practitioner (Site Contamination) scheme (CEnvP(SC)) or the Soil Science Australia Certified Professional Soil Scientist Contaminated Site Assessment and Management (CPSS CSAM) scheme.
 - b) be prepared in accordance with the relevant guidelines made or approved by the EPA under section 105 of the *Contaminated Land Management Act 1997*.

- c) Include, but not be limited to:
 - i. comment on the extent and nature of the remediation undertaken;
 - ii. if material is to remain in-situ and capped, describe the location, nature and extent of any remaining contamination on site as well as any ongoing management requirements;
 - iii. if treated material is to remain on the subject site, results of sampling of treated material, compared with the treatment criteria in the most updated RAP;
 - iv. results of any validation sampling, compared to relevant guidelines/criteria; and
 - v. comment on the suitability of the area for the intended land use.
 - d) be submitted to the Planning Secretary for review one month after the completion of remediation works
4. Prior to commencement of operation, the applicant must obtain confirmation from the Certifying Authority in writing that the requirements of **condition 3** have been met.

The EPA also reminds the applicant of the following:

1. The processes outlined in *State Environmental Planning Policy 55 – Remediation of Land* (SEPP55) are to be followed in order to assess the suitability of the land and any remediation required in relation to the proposed use.
2. The applicant must ensure the proposed development does not result in a change of risk in relation to any pre-existing contamination on the site so as to result in significant contamination [note that this would render the applicant the 'person responsible' for the contamination under section 6(2) of *Contaminated Land Management Act 1997* (CLM Act)].
3. The EPA should be notified under section 60 of the CLM Act for any contamination identified which meets the triggers in the Guidelines for the Duty to Report Contamination www.epa.nsw.gov.au/resources/clm/150164-report-land-contamination-guidelines.pdf
4. The EPA recommends use of "certified consultants". Please note that the EPA's *Contaminated Land Consultant Certification Policy* (<https://www.epa.nsw.gov.au/-/media/epa/corporate-site/resources/clm/18520-contaminated-land-consultant-certification-policy.pdf?la=en&hash=D56233C4833022719BCE0F40F870C19DC273A1F7>) supports the development and implementation of nationally consistent certification schemes in Australia, and encourages the use of certified consultants by the community and industry. Note that the EPA requires all reports submitted to the EPA to comply with the requirements of the CLM Act to be prepared, or reviewed and approved, by a certified consultant.