

20 April 2022

Our Ref: R/2016/15/H
File No: 2022/230025
Your Ref: SSD-7610-Mod-5

Lewis Demertzi
Department of Planning and Environment
via Planning Portal

**Advice on Modification Report
Inner Sydney High School – SSD-7610 Modification 5 – Façade Lighting**

Dear Lewis,

Thank you for your correspondence dated 5 April 2022 inviting the City of Sydney Council (the City) to comment on the submitted Section 4.55(1A) application to modify development consent SSD-7610 relating to Inner Sydney High School.

Modification 5 seeks consent for lights that have been installed on the northern, eastern and western facades of the newly constructed 13 storey Inner Sydney High School building.

The proposal has not adequately demonstrated compliance with the objectives and provisions of Section 3.2.8 – External Lighting in the *Sydney Development Control Plan 2012* and the *Exterior Lighting Strategy 2005 – Section 7.2*. The submitted lighting report is considered to be incomplete for assessment purposes. The following information is requested:

- Illumination designs, certified by a suitably qualified practising lighting engineer, confirming compliance with the following specifications:
 - Illuminance along opposite residential properties as per *AS4282:2019*
 - Calculations for spill light into the sky
 - Calculations for luminance of luminaires
 - Calculations for luminance of lit façade

The City does not object to proposal, however, it is requested that the above information be provided for approval.

Should you wish to speak with a Council officer about the above, please contact Samantha Kruize, Senior Planner on 9265 9333 or at skruize@cityofsydney.nsw.gov.au.

Yours sincerely,



Andrew Rees
Area Planning Manager (Major Projects)