

27 November 2020



Attention Ania Dorocinska
Senior Environmental Assessment Officer
Department of Planning, Infrastructure & Environment
Level 29, 320 Pitt Street
NSW 2170

Jemena Gas Networks
(NSW) Ltd
ABN 87 003 004 322

Level 14
99 Walker St
North Sydney NSW 2060
PO Box 1220
North Sydney NSW 2060
T +61 2 9867 7000
F +61 2 9867 7010
www.jemena.com.au

Dear Ania,

SSD- 10470

Property: 11 & 13 Percy Street, Auburn NSW 2144


Proposal: Proposed Woolworths Warehouse & Distribution Centre

Jemena Asset Management Pty Ltd on behalf of Jemena Gas Networks (NSW) Ltd (collectively Jemena) has reviewed and assessed the SSD-10470 and makes the comments and recommendations with respect to the location, operation and identification potential threats to gas mains.

Jemena confirms that it has no objections to the proposed development application in proximity to its gas main infrastructure.

In assessing the development application, Jemena can confirm that it operates a gas distribution network. The secondary gas main is situated within the road reserve of Percy Street on the opposite footpath alignment. The secondary gas main services low pressure gas mains at the connection level.

- Secondary gas main – steel 350 mm pipeline with 1050 kpa – Green Line



If you have any questions or queries about the above advice, please do not hesitate to contact the undersigned.

Kind Regards

A handwritten signature in blue ink, appearing to read 'Luke Duncan'.

Luke Duncan
Land Management