

From: Turvey David <David.Turvey@transgrid.com.au>
To: Andrew Hartcher <Andrew.Hartcher@planning.nsw.gov.au>
CC: Hobbs Graham <Graham.Hobbs@transgrid.com.au>
Date: 12/16/2011 8:50 am
Subject: WestPark Industrial Estate

Your Ref : SSD-4953
Our Ref 6372
File No : 2003/1735

Andrew,

WestPark Industrial Estate
Chemical Storage & Distribution Facility
Erskine Park Rd, ERSKINE PARK
Lot 1 DP 1128233

I refer to your correspondence dated the 6 December, 2011 regarding the abovementioned project.

This property is affected by existing Transmission Lines owned and maintained by TransGrid. These lines are protected by an easement 137.16metres. Easements are required to enable TransGrid access to the line for inspection and maintenance purposes. It also allows TransGrid the right to control any activity that may pose a risk to the line or to public safety.

The works proposed on this site will be clear of the existing Transmission Line easement and therefore TransGrid will have no objections to these works.

All work in the vicinity of overhead transmission lines has to be carried out in accordance with the WorkCover Code of Practice Act "Working Near Over Head Power Lines".

Therefore, the developers will need to be notified of TransGrids comments in this respect.

If you require any further information or should the developers have any queries in this regard then contact should be made with myself or Mr Graham Hobbs on (02) 9620 0777.

regards

David Turvey
Easement Officer| Land Assets and Facilities

TransGrid | 200 Old Wallgrove Rd EASTERN CREEK
T: (02) 9620 0218 M: XXXX XXX XXX
F: (XX) XXXX XXXX E: david.turvey@transgrid.com.au<mailto:name.surname@transgrid.com.au> W:
www.transgrid.com.au<http://www.transgrid.com.au>