

Peter McManus - ASA RESPONSE: Wagga Wagga Base Hospital Redevelopment (NSW-MA-187)

From: "Neidert, Jessica" <Jessica.Neidert@AirservicesAustralia.com>
To: Peter McManus <Peter.McManus@planning.nsw.gov.au>
Date: 5/27/2013 3:03 PM
Subject: ASA RESPONSE: Wagga Wagga Base Hospital Redevelopment (NSW-MA-187)

Hi Peter

I refer to your request for the assessment of Wagga Wagga Base Hospital redevelopment, NSW.

The highest elevation of the proposed hospital and helipad is 220.745m AHD. On the basis that the height provided is in AHD and the hospital redevelopment distance of 6 nautical miles from ARP, the proposed structure will not be significant to Wagga Wagga instrument procedures. However, if the actual top height of the structure is higher than 220.745m AHD, further obstacle assessment is necessary to determine its impact to instrument procedures at Wagga Wagga aerodrome.

On the basis that the proposed development site is approximately 10 km from Wagga Wagga airport and that there are no Airservices Communications, Navigation or Surveillance facilities within this 10 km radius, the proposed development will not adversely impact the performance of Airservices Precision/Non-Precision Nav Aids, HF/VHF Comms, A-SMGCS, Radar, PRM, ADS-B, WAM or Satellite/Links.

Please feel free to contact me if you have any enquires.

Kind Regards

Jessica Neidert

Airport Development Assistant | C&IA Group

Our Values: Excellence, Inclusion, Cohesion, Initiative

Tel: +61 2 6268 4725 | Fax: +61 2 6268 4003

E-mail: jessica.neidert@airservicesaustralia.com

CAUTION: This e-mail is confidential. If you are not the intended recipient, you must not disclose or use the information contained in it. If you have received this e-mail in error, please tell us immediately by return e-mail and delete the document. Airservices Australia does not represent, warrant or guarantee that the integrity of this communication is free of errors, virus or interference.