

Calibre Consulting (NSW) Pty Ltd
Level 2, 2 Burbank Place
Norwest Business Park NSW 2153
PO Box 8300
Baulkham Hills BC NSW 2153
T +61 2 8808 5000
ABN 30 109 434 513



Our Ref: X12254.i
Your Ref: i
Contact: Peter Wiggan

19 March 2015

Gazcorp Pty Ltd
PO Box 732
Gladesville NSW 2111

Attention: Michael de Silva

Dear Sir,

Proposed Industrial Development, 813 – 913 Wallgrove Road, Eastern Creek.

Amendment to Proposed Road Layout

Please find attached the amended concept plan for water and sewer servicing for the proposed industrial subdivision at 813 – 913 Wallgrove Road, Eastern Creek. In our opinion the amended road layout does not change the sizing of the lead in water mains or sewer as shown on the attached preferred option concept plan.

Please note that the preferred option to provide water supply from the Minchinbury Elevated Reservoir to the north of the site differs from Sydney Water's original feasibility advice in May, 2012 which recommended supply from the Cecil Hills reservoir to the south. At this stage, Sydney Water has not approved or confirmed the Minchinbury Elevated water servicing strategy.

Yours Sincerely,

A handwritten signature in dark ink, appearing to read 'P. Wiggan', with a long horizontal flourish extending to the right.

Peter Wiggan
Senior Project Manager
Calibre Consulting

ATTACHMENTS

1. Attachment 1 - Revised Water and Sewer Preferred Servicing Strategy

COPIES

1. Peter Fagin