

File Ref. No: FRN13/5127 (3923)  
TRIM Doc. No: D13/27014  
Contact: Alan Bruce

25 June 2013

NSW Planning and Infrastructure  
213-33 Bridge Street  
SYDNEY NSW 2000

Email: [ashley.cheong@planning.nsw.gov.au](mailto:ashley.cheong@planning.nsw.gov.au)

Attention: Ashley Cheong

Dear Sir,

**Re: Penrith Glass Beneficiation Plant (SSD 5267) - 126 Andrews Road, PENRITH**

I refer to your correspondence dated 5 June 2013, requesting comment from Fire and Rescue NSW (FRNSW) on a Development Application (DA) for the above project (SSD5267).

The submission consists of an Environmental Impact Statement (EIS) prepared by Samuel Grieve, Duke Ismael and Linda Zanolto of Benbow Environmental. (111144\_EIS\_Rep\_Final) and is dated 29 May 2013.

The reporting officer has reviewed the submitted EIS and the following comments are provided:

1. FRNSW would expect any new building proposals and substantial alterations to existing buildings to comply with the current BCA and relevant Australian Standards.
2. Access to any existing street hydrants or installed fire hydrant and sprinkler installations, that are currently located to protect existing buildings and associated infrastructure, should not be compromised by the proposed changes and during the development of the site.

Should you have any further enquiries regarding any of the above matters, please do not hesitate to contact the Structural Fire Safety Unit.

Yours faithfully

*6004 Mark Porter*

Station Officer Mark Porter  
Acting Team Leader  
Building Fire Safety Unit

