



016

Ms Susan Fox  
Senior Planning Officer – Industry Assessments  
Department of Planning & Environment  
GPO BOX 39  
SYDNEY NSW 2001

**APPLICATION**

**DE-2018/215**

Date

4 July 2019

Dear Ms Fox

## **STATE SIGNIFICANT DEVELOPMENT – KEMBLA GRANGE RESOURCE RECOVERY FACILITY (SSD 5300 MOD 2) – COMMENTS ON RESPONSE TO SUBMISSIONS**

Thank you for notifying Council of the response to submissions by the proponent for the above Modification Request.

The supporting documentation has been reviewed and Council considers that matters raised in Attachment A our previous submission dated 19 December 2018 have been addressed with the exception of the following matter:

- The 'Blown Material Cage' appears to interact with the turning movements and site access arrangement for the site. The turn path provided on Drawing C305 Job no. KF110816, Revision D, dated 09/10/2018 utilises a Heavy Rigid Vehicle at the location adjacent to the 'Blown Material Cage' when the design vehicle for the rest of the site is an Articulated Vehicle.

If you have any enquiries or wish to discuss these matters, please contact Vivian Lee, Senior Development Project Officer on (02) 4227 7314.

Yours faithfully



**Greg Doyle**  
General Manager  
Wollongong City Council

