

**MANAGING DIRECTORS**

MATTHEW PALAVIDIS  
VICTOR FATTORETTO

**DIRECTORS**

MATTHEW SHIELDS  
BEN WHITE



18/09/2013

20101130.2/1809A/R0/GW

Capital Corporation Properties Pty Ltd  
Attn: Maria Passafaro  
PO Box 6285  
BAULKHAM HILLS BC NSW 2153

## Stage 1a and Stage 2, 2 Australia Ave Olympic Park- Respond to Sydney Olympic Park Authority Letter dated 09 Sep 2013

This letter is to clarify noise impacts issue raised in letter by Sydney Olympic Park Authority dated 09 September 2013 which has been repeated below.

### Noise Impacts

The consultant's Acoustic Report is noted and, although not directly stated, it is inferred that the glazing thickness recommendations (p11 of the consultant's report) have considered the noise emissions from major events. This should be clarified.

Noise levels of typical event have been measured by this office, provided glazing thickness recommendations in Page 11 of acoustic reports the internal noise levels will satisfy requirements by Australian Standard AS2107-2000.

We trust this information is satisfactory. Please contact us should you have any further queries.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'George Wei', is positioned above the printed name.

George Wei

Acoustic Logic Consultancy Pty Ltd

Senior Acoustic Engineer

SYDNEY MELBOURNE BRISBANE CANBERRA LONDON DUBAI SINGAPORE GREECE

T: (02) 8339 8000 | F: (02) 8338 8399 | 9 Sarah St MASCOT NSW 2020

[www.acousticlogic.com.au](http://www.acousticlogic.com.au)

The information in this document is the property of Acoustic Logic Consultancy Pty Ltd ABN 11 068 954 343 and shall be returned on demand. It is issued on the condition that, except with our written permission, it must not be reproduced, copied or communicated to any other party nor be used for any purpose other than that stated in particular enquiry, order or contract with which it is issued.