

ENQUIRIES: DAVID QUIGLEY  
PROJECT NO: 27024

7 March 2017

Lend Lease (Haymarket) Pty Limited  
Level 4, The Bond  
MILLERS POINT NSW 2000

Attention: Matthew Kennedy


Dear Sir

**RE: RELOCATED FIRE WATER STORAGE TANK FOR THE NORTH EAST PLOT  
DEVELOPMENT AT DARLING SQUARE**

The relocated Fire Water Storage Tank for the North East Plot Development at Darling Square has been sized in accordance with the requirements of AS 2118.6-2012 Automatic Fire Sprinkler Systems – Part 6: Combined Sprinkler and Hydrant Systems in Multistorey Buildings.

Access Requirements for the Fire Water Storage Tank for the North East Plot Development at Darling Square are in line with the requirements of AS 2304-2011 Water Storage Tanks for Fire Protection Systems.

Yours faithfully



**David Quigley**  
for **Wood & Grieve Engineers**