

Your ref 238627
Our ref
File ref

ARUP

Mona Suen
For and on behalf of Atelier Pacific Ltd.
3501 Two Chinachem Exchange Square
338 King's Road
North Point
Hong Kong

Level 10 201 Kent Street
PO Box 76 Millers Point
Sydney 2000
Australia

t +61 2 9320 9320
d +61 2 9320 9520
f +61 2 9320 9321

nick.howard@arup.com
www.arup.com

27 August 2015

Dear Mona

Fendi Fitout, DFS, Sydney - Fire Services Design Certification

Subject to the documents being amended in accordance with our design review I certify the above design as follows:

Pursuant to the provisions of Clause A2.2 of the Building Code of Australia, I hereby certify that the above design is in accordance with normal engineering practice and meets the requirements of the applicable Building Code of Australia and relevant Australian Standards, including;

AS2118.1-1999
AS2419.1-2005
AS2441-2005
AS 1670- 2004

I am an appropriately qualified and competent person in this area and as such can certify that the design complies with the above.

Full Name of Designer:	Nick Howard, Associate Principal, Arup.
Qualifications:	BEng (Hons) CEng CPEng FIPHE FSoPHE MCIBSE MCIWEM MIEAust NPER
Address of Designer:	Level 10, 201 Kent Street, Sydney, 2000
Business Telephone No:	02 9320 9354
Name of Employer:	Arup Pty Ltd

Yours sincerely



Nick Howard
Associate Principal