

28.06.2019

Ref: SY182476-ML01-3

Loreto  
C/- Bloompark Consulting Pty Ltd  
Suit 2.04/41 McLaren Street  
North Sydney NSW 2060

Dear Byron,

**Re: Loreto Kirribilli Innovation Centre - SSD Modifications**

The following modifications to the SSD documents have been made to the mechanical services design for Loreto Kirribilli Innovation Centre:

- Kitchen make up air to be provided from roof level rather than from the façade;
- AHU (air handling unit) to serve Ground Level air conditioning rather than serve as a dedicated outside air system, and;
- Mixed-mode natural ventilation is achieved through the fans in the FCUs (fan coil units) within each space rather than via louvres due to acoustic requirements.

The above modifications to the SSD documents do not have any significant impact to the nature of the original DA.

Yours sincerely,

A handwritten signature in black ink, appearing to read "Andy Liu", with a stylized flourish at the end.

Andy Liu  
Mechanical Engineer  
Northrop Consulting Engineers Pty. Ltd.

Date	Rev	Issue	Author	Verifier
04.06.2019	1	For Information	A. Liu	L. Mathews
25.05.2019	2	For Information	A. Liu	L. Mathews
28.06.2019	3	For Information	A. Liu	L. Mathews