

20190205.10/2403A/R0/TA

24/03/2020

Loreto Kirribilli  
85 Carabella Street  
KIRRIBILLI NSW 2061  
AUSTRALIA

Attn: Byron Williams

**Loreto Kirribilli Innovation Centre - S4.55 Advice - Mechanical Plant Relocation**

This letter has been prepared to address the proposed mechanical plant relocation within the Loreto Kirribilli Innovation Centre.


Proposed relocations are as follows:

- Seven condensers relocated from Roof Terrace (west) to Ground level next to Driveway.
- Kitchen exhaust and make up ductwork/ fans relocated off Roof Terrace (east). Exhaust moved to facade at Ground Floor driveway, and make up air at LG2 facade east of Food Tech Kitchen
- Dust Extractor originally on Ground floor driveway relocated to LG1 underground plant room

We confirm that these relocations are acceptable from an acoustic perspective and noise emissions from the relocated mechanical plant will comply with the noise emission requirements of Condition of Consent B6.

We trust this information is satisfactory. Please contact us should you have any further queries.

Yours faithfully,



Acoustic Logic Consultancy Pty Ltd  
Thomas Aubusson  
MAAS

---

**SYDNEY**  
9 Sarah St  
MASCOT NSW 2020  
(02) 8339 8000

ABN 11 068 954 343  
[www.acousticlogic.com.au](http://www.acousticlogic.com.au)

The information in this document is the property of Acoustic Logic Consultancy Pty Ltd ABN 11 068 954 343 and shall be returned on demand. It is issued on the condition that, except with our written permission, it must not be reproduced, copied or communicated to any other party nor be used for any purpose other than that stated in particular enquiry, order or contract with which it is issued.