

Patrick Copas

From: Paul Byleveld [REDACTED]
Sent: Tuesday, 9 July 2019 4:43 PM
To: Pamela Morales
Cc: Paul Williamson; Anthony Kohlenberg (Mid North Coast LHD)
Subject: consent condition : North Byron Parklands

Follow Up Flag: Follow up
Flag Status: Flagged

Dear Pamela

I have discussed with colleagues at the North Coast Public Health Unit. Noting that NSW Health has no formal responsibility to approve QAPs, we would recommend the following consent condition:

At least two months prior to the first outdoor event, the Applicant must prepare a Drinking Water Quality Assurance Program for the development. The Applicant must:

- (a) ***ensure that the Quality Assurance Program complies with the Public Health Regulation 2012;***
- (b) ***comply with its Quality Assurance Program;***
- (c) ***provide a copy of the Quality Assurance Program, and any subsequent amendments, to NSW Health (North Coast Public Health Unit); and***
- (d) ***address any feedback provided by NSW Health on its Quality Assurance Program.***

A copy of the Quality Assurance Program provided to NSW Health, and any subsequent amendments, must be submitted to the Planning Secretary.

I understand that the Public Health Unit will share a copy of its response to the applicant regarding its quality assurance program.

Kind regards Paul

Dr Paul Byleveld PSM

Manager Water Unit | **Environmental Health Branch** | **NSW Health**
Locked Mail Bag 961 NORTH SYDNEY NSW 2059

[REDACTED]
www.health.nsw.gov.au/environment/water

Water Unit on-call 02 9391 9939 | 0491 227 423

