

Rhys Edwards

From: Tim Bell <Tim.Bell@wsc.nsw.gov.au>
Sent: Tuesday, 27 September 2016 9:37 AM
To: Edwards, Rhys - ACOR
Subject: RE: Bowral & District Hospital - Authority Sewer capacity

Hi Rhys,

Sorry about the long delay in replying to your request. I've checked our sewer model and can see negligible impact on the sewer system for the proposed development of Bowral Hospital.

There is sufficient capacity available in the downstream sewer as per your proposed connection plan and peak flows.

If you have any questions, feel free to contact me.

Cheers,

Tim Bell Modelling & Systems Engineer
Wingecarribee Shire Council
e. tim.bell@wsc.nsw.gov.au
t. (02) 4868 0816 m. 0427 111 997

Civic Centre, 68 Elizabeth St. Moss Vale, NSW 2577 | PO Box 141 Moss Vale NSW 2577


www.wsc.nsw.gov.au

From: Edwards, Rhys - ACOR [<mailto:REdwards@acor.com.au>]
Sent: Friday, 22 July 2016 3:28 PM
To: Tim Bell
Subject: RE: Bowral & District Hospital - Authority Sewer capacity

Hi Tim,
An update on the sewer capacity would be handy.

Cheers,

Rhys Edwards | Associate Hydraulic Engineer



ENGINEERS | MANAGERS | INFRASTRUCTURE PLANNERS | DEVELOPMENT CONSULTANTS

ACOR Consultants Pty Ltd

Suite 2, Level 1, 33 Herbert St
St Leonards NSW 2065

T +61 2 9438 5098 | M 0421 760 925
E REdwards@acor.com.au



www.acor.com.au | Careers

This email and any files transmitted with it are intended solely for the use of the addressee(s) and may contain information that is confidential or subject to legal privilege. If you receive this email and you are not the addressee (or responsible for delivery of the email to the addressee), please note that any copying, distribution or use of this email is prohibited and as such, please disregard the contents of the email, delete the email and notify the sender immediately. There is no warranty that this email is error or virus free. It may be a private communication containing opinions personal to the sender and/or the person with whom the sender is communicating, and if so, does not represent the view of ACOR Consultants Pty Ltd, ACN 079 306 246 ABN 40 079 306 246 its subsidiaries, related parties and/or affiliates.

From: Tim Bell [<mailto:Tim.Bell@wsc.nsw.gov.au>]
Sent: Friday, 24 June 2016 10:19 AM
To: Edwards, Rhys - ACOR
Subject: RE: Bowral & District Hospital - Authority Sewer capacity

Hi Rhys,

Generally with these applications we will complete the work, send the report and an invoice will follow.

I've been flat out lately so haven't had a chance to process your application yet. Hope to have the report to you by end of next week.

Cheers,

Tim Bell Modelling & Systems Engineer

Wingecarribee Shire Council

Civic Centre, Elizabeth St. Moss Vale, NSW 2577 | PO Box 141 Moss Vale NSW 2577. DX 4961 Bowral

t: (02) 4868 0816 f: (02) 4869 1203 m: 0427 111 997

e: tim.bell@wsc.nsw.gov.au

www.wsc.nsw.gov.au

From: Edwards, Rhys - ACOR [<mailto:REdwards@acor.com.au>]
Sent: Wednesday, 8 June 2016 11:06 AM
To: Tim Bell
Subject: RE: Bowral & District Hospital - Authority Sewer capacity

Hi Tim,

Please find attached the completed application form. Trust all is in order. If additional information is required please let me know.

Assuming an invoice will be sent shortly for us to pay pre assessment is carried out. If you could advise on this matter, I can have our accounts release the money.

Regards,

Rhys Edwards | Associate Hydraulic Engineer



ENGINEERS | MANAGERS | INFRASTRUCTURE PLANNERS | DEVELOPMENT CONSULTANTS

ACOR Consultants Pty Ltd

Suite 2, Level 1, 33 Herbert St
St Leonards NSW 2065



T +61 2 9438 5098 | M 0421 760 925

www.acor.com.au | Careers

This email and any files transmitted with it are intended solely for the use of the addressee(s) and may contain information that is confidential or subject to legal privilege. If you receive this email and you are not the addressee (or responsible for delivery of the email to the addressee), please note that any copying, distribution or use of this email is prohibited and as such, please disregard the contents of the email, delete the email and notify the sender immediately. There is no warranty that this email is error or virus free. It may be a private communication containing opinions personal to the sender and/or the person with whom the sender is communicating, and if so, does not represent the view of ACOR Consultants Pty Ltd, ACN 079 306 246 ABN 40 079 306 246 its subsidiaries, related parties and/or affiliates.

-----Original Message-----

From: Tim Bell [<mailto:Tim.Bell@wsc.nsw.gov.au>]
Sent: Friday, 3 June 2016 1:36 PM
To: Edwards, Rhys - ACOR
Subject: RE: Bowral & District Hospital - Authority Sewer capacity

Hi Rhys,

No problems. Thanks for the update and congrats!

Cheers,
Tim

-----Original Message-----

From: Edwards, Rhys - ACOR [<mailto:REdwards@acor.com.au>]
Sent: Friday, 3 June 2016 1:03 PM
To: Tim Bell
Subject: Re: Bowral & District Hospital - Authority Sewer capacity

Hi Tim, definitely will send the application. I've been on paternity leave (exciting times ahead). So I'm just catching up on things. Will submit app early next week.

Thanks for following this up.

Cheers

Sent from my iPhone

On 3 Jun 2016, at 9:33 AM, Tim Bell <Tim.Bell@wsc.nsw.gov.au<<mailto:Tim.Bell@wsc.nsw.gov.au>>> wrote:

Hi Rhys,

I haven't received an application for the sewer assessment. Do you wish to proceed with this development assessment?

If so, please complete the form and send back to me at your earliest convenience.

Regards,

Tim Bell Modelling & Systems Engineer
Wingecarribee Shire Council
Civic Centre, Elizabeth St. Moss Vale, NSW 2577 | PO Box 141 Moss Vale NSW 2577. DX 4961 Bowral
t: 0248 680 816 f: (02) 4869 1203 m: 0427 111 997

e: tim.bell@wsc.nsw.gov.au<<mailto:tim.bell@wsc.nsw.gov.au>>

www.wsc.nsw.gov.au<<http://www.wsc.nsw.gov.au>>