

From: Easements&Development <Easements&Development@transgrid.com.au>

Sent: Friday, 14 September 2018 12:50 PM

To: Olivia Hirst <Olivia.Hirst@planning.nsw.gov.au>

Subject: HPE CM: 2018-111 Proposed ASICS Facility : Request for Input to Secretary's Environmental Assessment Requirements

TransGrid Reference Number: 2018-111

Proposal: Proposed ASICS Facility : Request for Input to Secretary's
Environmental Assessment Requirements

Location: 4 Darling Street, Marsden Park (SSD 9153)
Part Lots 303 & 304 and Lot 305 in DP 1213756

TransGrid: Transmission Line 1 Feeder 20 Structure Span 37 – 39 Sydney West –
Sydney North

Thank you for referring the above mentioned Development Application to TransGrid for review.

Please be advised after reviewing the proposed works at **Proposed ASICS Facility : Request for Input to Secretary's Environmental Assessment Requirements**

TransGrid has determined the proposed works acceptable subject to the following conditions of approval being met:

Technical Conditions:

Revised plans are reviewed and assessed:

- The document “ 2018-08-30 Appendix A Response to TransGrid Submissions” demonstrates the issues raised by TransGrid, have been resolved by the client.
- The proposal is acceptable.

Access and Maintenance Conditions:

- TransGrid will require unobstructed access way to the structure and the 20m exclusion zone around the structure will need to be maintained – safe & unobstructed working platforms need to be preserved around the structures for access to and for the setting up of EWP's, cranes and other large plant and equipment
- Access to the Transmission Line and structures to be made available at all times (24x7) for TransGrid plant & personnel
- Please be advised that the insulators on the structure at the site are old and any earthworks would have an adverse impact on these
- It is recommended that the changing of the insulators and fittings on the structure become a part of the approval for this development at the proponent cost

Regards

Michael

Michael Platt

Development Assessment and Control Officer | Network Planning and Operations

TransGrid | 200 Old Wallgrove Road, Wallgrove, NSW, 2766

T: (02) 9620 0161 **M:** 0427 529 997

E: Michael.Platt@transgrid.com.au **W:** www.transgrid.com.au

Disclaimer:

This e-mail may contain privileged and confidential information intended only for the addressees named above. If you are not the intended recipient please delete this e-mail and advise the sender. TransGrid's Privacy Policy is available on our website <https://www.transgrid.com.au/privacy>. Any use, dissemination, distribution, reproduction of this email is prohibited. Unless explicitly attributed, the opinions expressed in this e-mail are those of the author only and do not represent the official view of TransGrid. E-mail communications with TransGrid may be subject to automated e-mail filtering, which could result in the delay or deletion of a legitimate e-mail before it is read by its intended recipient. TransGrid does not accept liability for any corruption or viruses that arise as a result of this e-mail. Please consider the environment before printing this e-mail.