

From: [REDACTED]
To: [Rob Beckett](#)
Cc: [Fire Safety](#)
Subject: Walla Walla Solar Far (SSD-9874) - Response to Submissions. BFS20/981
Date: Wednesday, 8 April 2020 11:21:58 AM
Attachments: [image015.png](#)
[image016.png](#)
[image017.png](#)
[image018.png](#)
[image019.png](#)
[image020.png](#)
[image021.png](#)

Walla Walla Solar Far (SSD-9874) - Response to Submissions

Dear Rob,

I refer to the submission of the request for agency input into the Response to Submissions Report for the Walla Walla Solar Farm Project (SSD 9874), dated 2nd April 2020. The relevant parts of the proponent's Response to Submissions report have been reviewed and the following comments are submitted for consideration.

FRNSW reaffirm previous correspondence dated 21st November 2019, which outlines the *request that FRNSW be given the opportunity to review and provide comment on any proposed modification to the development that includes the installation of a Battery Energy Storage Systems (BESS).*

For further information please contact the Fire Safety Infrastructure Liaison Unit, referencing FRNSW file number BFS20/981. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Regards
Brendan

Fire and Rescue NSW



A/INSPECTOR BRENDAN HURLEY
TEAM LEADER INFRASTRUCTURE LIAISON
FIRE SAFETY | Fire and Rescue NSW

[REDACTED]
1 Amarina Ave, Greenacre, NSW 2190



www.fire.nsw.gov.au



FRNSW CONFIDENTIALITY NOTICE AND DISCLAIMER

The information in this transmission may be confidential and/or protected by legal professional privilege, and is intended only for the person or persons to whom it is addressed. If you are not the intended recipient of this message you must not read, forward, print, copy, disclose, use or store in any way the information in this e-mail or any attachment it may contain. Please notify the sender immediately and delete or destroy all copies of this e-mail and any attachment it may contain.

Views expressed in the message are those of the individual sender, and are not necessarily the views of Fire and Rescue NSW (FRNSW). Use of electronic mail is subject to FRNSW policy and guidelines. FRNSW reserves the right to filter, inspect, copy, store and disclose the contents of electronic mail messages, as authorised by law.

This message has been scanned for viruses.
