

The Secretary  
NSW Planning, Industry & Environment

23 June 2021

**ATTENTION: Michelle Niles**

Dear Sir or Madam

I refer to the Department's below email of 17 June 2021 regarding the public exhibition of the Environmental Impact Statement (EIS) for State Significant Development SSD-10224 New Primary School at Edmondson Park for 'New primary school including 1000 primary school students and a pre-school' at Buchan Avenue, Edmondson Park (Lots 1 and 2 DP 1257105) in the Liverpool City Local Government Area. Submissions need to be made to the Department by 14 July 2021.

Please also refer to Endeavour Energy's previous submission made to the Department via email on 23 November 2020 regarding the request for Secretary's Environmental Assessment Requirements (SEARs) for State Significant Development SSD-10244 Edmondson Park School for new primary and secondary school including 1000 primary school students, 2000 secondary school students with commercial additions including a pre-school and research hub at Buchan Avenue, Edmondson Park in the City of Liverpool Council Local Government Area (LGA).

As shown in the below site plans from Endeavour Energy's G/Net master facility model (and extract from Google Maps Street View) there is:

- An easement benefitting Endeavour Energy (indicated by red hatching) for overhead power lines which currently has no 'Inservice' electricity infrastructure.
- Low voltage and 11,000 volt / 11 kilovolt (kV) high voltage underground cables to the Buchan Avenue road verge / roadway.

Please note the location, extent and type of any electricity infrastructure, boundaries etc. shown on the plan is indicative only. In addition it must be recognised that the electricity network is constantly extended, augmented and modified and there is a delay from the completion and commissioning of these works until their capture in the model. Generally (depending on the scale and/or features selected), low voltage (normally not exceeding 1,000 volts) is indicated by blue lines and high voltage (normally exceeding 1,000 volts but for Endeavour Energy's network not exceeding 132,000 volts / 132 kV) by red lines (these lines can appear as solid or dashed and where there are multiple lines / cables only the higher voltage may be shown). This plan only shows the Endeavour Energy network and does not show electricity infrastructure belonging to other authorities or customers owned electrical equipment beyond the customer connection point / point of supply to the property. This plan is not a 'Dial Before You Dig' plan under the provisions of Part 5E 'Protection of underground electricity power lines' of the *Electricity Supply Act 1995* (NSW).


In regard to the easement over the site for overhead power lines, as shown in the following extract of the Architectural Design Report dated June 2021 '(E) overhead power lines and associated power poles on Survey have been demolished prior to this development'.

## 7 Existing Site Development History

SEARS Item 5

(E) BOUNDARY FENCE TO BE DEMOLISHED FOR (N) SCHOOL ENTRY FORECOURT

(E) OVERHEAD POWER LINES AND ASSOCIATED POWER POLES ON SURVEY HAVE BEEN DEMOLISHED PRIOR TO THIS DEVELOPMENT



Endeavour Energy's Property Branch has provided the following advice:

*About a month ago Landcom approached Endeavour to sign a NSW Land Registry Services (LRS) dealing to release the easement. This has occurred and the dealing has been returned to Landcom to lodge with LRS.*

Subject to the foregoing and the following recommendations and comments Endeavour Energy has no objection to the Development Application:

- Network Capacity / Connection

Endeavour Energy has noted the following in the Infrastructure Management Plan regarding the suitability of the site for the development in regard to whether electricity services are adequate for the development.

### 2.2.2 NEW KIOSK SUBSTATION AND NEW MAIN SWITCHBOARD

#### 2.2.2.1 ESTABLISHMENT OF NEW KIOSK SUBSTATION AND NEW MAIN SWITCHBOARD

Based on the maximum demand calculated for new primary school in Edmondson Park is a new 1000kVA kiosk substation and new main switchboard are proposed to be installed on site.


The new 1000kVA KL kiosk substation is proposed to be fused at 1600 Amps LV in a 1600 Amps LV panel with the SPD set at 1000 Amps at the new site MSB.

#### 2.2.2.2 NEW KIOSK SUBSTATION

JHA have carried out a desktop study for a feasibility on the new substation locations.

There are numerous restrictions and easements required to be considered when locating a suitable location such as factoring a 5300mm x 3300mm easement for the kiosk substation arrangement, 3m fire separation restriction to non 2 hr. FR structures, 10m away from fire boosters, 6m to any ventilation openings). The configuration of substation explored are in the form of an outdoor KL Kiosk Substation or KK Kiosk Substation.

Based on the requirements above, JHA have proposed the following location for the new KL kiosk substation which is located on the Buchan Avenue street frontage as per Figure 2.3.




From Endeavour Energy's perspective the fact that provision is being made for a padmount substation is a positive. Endeavour Energy's general requirements is for a padmount substation to be at ground level and have direct access from a public street (unless provided with appropriate easements for the associated underground cables and right of access).

As shown in the following extract of Endeavour Energy's Mains Design Instruction MDI 0044 'Easements and Property Tenure Rights', Figure A4.3 'Padmount easements and clearances', padmount substations require:

- Easement with a minimum size of 2.75 x 5.5 metres (single transformer).
- Restriction for fire rating which usually extends 3 metres horizontally from the base of the substation footing / plinth and 6 metres vertically from the same point.
- Restriction for swimming pools which extends 5 metres from the easement.

#### A4.3 - Padmount easements and clearances



The easement should not cross property boundaries but the restriction/s may affect any adjoining property provided they are able to be registered on the title to that property. In addition the following matters also need to be considered in regard to the fire restriction:

- Personnel access doors and fire exit doors to a building are not permitted within the fire restriction area.
- Gas mains/pipes shall not pass through the fire restriction area.
- A 10 metre clearance distance shall be maintained between substation and fire hydrants, booster valves, and the like in accordance with AS2419.1 'Fire hydrant installations System design, installation and commissioning' as updated from time to time.
- Consideration should be provided to the appropriateness of the landscaping relative to the fire restriction for the substation. Any landscaping that potentially could transfer / provide connectivity for flame or radiant heat from a fire in the substation to a dwelling or building should be avoided.
- The storage of and / or use of flammable, combustible, corrosive or explosive material within the fire restriction should be avoided.

Generally it is the Level 3 Accredited Service Provider's (ASP) responsibility (engaged by the developer) to make sure that the substation location and design complies with Endeavour Energy's standards the suitability of access, safety clearances, fire ratings, flooding etc. As a condition of the Development Application consent the Department should request the submission of documentary evidence from Endeavour Energy confirming that satisfactory arrangements have been made for the connection of electricity and the design requirements for the substation, prior to the release of the Construction Certificate / commencement of works.

In due course the applicant for the proposed development of the site will need to submit an appropriate application based on the maximum demand for electricity for connection of load via Endeavour Energy's Network Connections Branch to carry out the final load assessment and the method of supply will be determined. Straightforward applications can be completed online and permission to connect may be provided immediately if submitting a complying application.

Depending on the outcome of the assessment, any required padmount substations will need to be located within the property (in a suitable and accessible location) and be protected (including any associated cabling) by an easement and associated restrictions benefiting and gifted to Endeavour Energy. Please refer to Endeavour Energy's Mains Design Instruction MDI 0044 'Easements and Property Tenure Rights'. As well as the capacity of distribution substations, other factors such as the size and rating / load on the conductors and voltage drop (which can affect the quality of supply particularly with long conductor runs) etc. need to be assessed.

For more complex connections, advice on the electricity infrastructure required to facilitate the proposed development can be obtained by submitting a Technical Review Request to Endeavour Energy's Network Connections Branch, the form for which FPJ6007 is attached. The response to these enquiries is based upon a desktop review of corporate information systems, and as such does not involve the engagement of various internal stakeholders in order to develop a 'Connection Offer'. It does provide details of preliminary connection requirements which can be considered by the applicant prior to lodging a formal application for connection of load.

Further details are available by contacting Endeavour Energy's Network Connections Branch via Head Office enquiries on business days from 9am - 4:30pm on telephone: 133 718 or (02) 9853 6666 or on Endeavour Energy's website under 'Home > Residential and business > Connecting to our network' via the following link:

<http://www.endeavourenergy.com.au/> .

Alternatively the applicant may need to engage an Accredited Service Provider (ASP) of an appropriate level and class of accreditation to assess the electricity load and the proposed method of supply for the development. The ASP scheme is administered by Energy NSW and details are available on their website via the following link or telephone 13 77 88:

<https://energy.nsw.gov.au/government-and-regulation/legislative-and-regulatory-requirements/asp-scheme-and-contestable-works> .

- Network Asset Design

Endeavour Energy's Company Policy 9.2.5 'Network Asset Design', includes the following requirements for electricity connections to new urban subdivision / development.

## **5.11 Reticulation policy**

### *5.11.1 Distribution reticulation*

In order to improve the reliability performance of and to reduce the operating expenditure on the network over the long term the company has adopted the strategy of requiring new lines to be either underground cables or where overhead is permitted, to be predominantly of covered or insulated construction. Notwithstanding this strategy, bare wire overhead construction is appropriate and permitted in some situations as detailed below.

In areas with the potential for significant overhanging foliage, CCT is used to provide increased reliability as it is less susceptible to outages from wind-blown branches and debris than bare conductors. CCT must only be used in treed<sup>2</sup> areas as the probability of a direct lightning strike is low. In open areas where the line is not shielded from a direct lightning strike, bare conductors must generally be used for 11kV and 22kV reticulation.

Non-metallic Screened High Voltage Aerial Bundled Cable (NMSHVABC) must be used in areas which are heavily treed and where it is not practicable to maintain a tree clearing envelope around the conductors.

---

<sup>2</sup> A "treed" area is one with a substantial number of trees adjacent to the line, in each span. In these situations CCT is used to provide increased reliability as it is less susceptible to outages from wind-blown

5.11.1.1 Urban areas

Reticulation of new residential subdivisions will be underground. In areas of low bushfire consequence, new lines within existing overhead areas can be overhead, unless underground lines are cost justified or required by either environmental or local council requirements.

Where underground reticulation is required on a feeder that supplies a mixture of industrial, commercial and/or residential loads, the standard of underground construction will apply to all types of load within that development.

Where ducting is used, adequate spare ducts and easements must be provided at the outset to cover the final load requirements of the entire development plan.

Extensions to the existing overhead 11kV/22kV network must generally be underground. Bare wire will be used for conductor replacements and augmentations except in treed areas where CCT or NMSHVABC must be used.

Extensions to the existing overhead LV network and augmentations must either be underground or ABC. Conductor replacements greater than 100m in route length must utilise aerial bundled cable.

- Bushfire

Endeavour Energy has noted the EIS indicates ‘the site is bushfire prone land comprising vegetation category 2 at the northern portions, and vegetation category 3 and vegetation buffer in the southern portion of the site’. The accompanying Bushfire Assessment Report which provides an assessment of the site having regards to NSW Rural Fire Service ‘Planning for Bush Fire Protection 2019’ includes the following advice.

3.5 Water supply and utilities

Electricity supply

Electrical supply will be provided underground and therefore complies with PBP.

NSW Rural Fire Service ‘Planning for Bush Fire Protection 2019’ provides the following advice:

Chapter 6 ‘Special Fire Protection Purpose Developments’

6.8.3 Services – Water, gas and electricity

**Intent of measures:** to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.

Table 6.8c

Performance criteria and acceptable solutions for water, electricity and gas services for SFPP development.

	PERFORMANCE CRITERIA	ACCEPTABLE SOLUTIONS
	The intent may be achieved where:	
ELECTRICITY SERVICES	<ul style="list-style-type: none"> <li>location of electricity services limits the possibility of ignition of surrounding bush land or the fabric of buildings.</li> </ul>	<ul style="list-style-type: none"> <li>where practicable, electrical transmission lines are underground;</li> <li>where overhead, electrical transmission lines are proposed as follow:                             <ul style="list-style-type: none"> <li>lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and</li> <li>no part of a tree is closer to a power line than the distance set out in accordance with the specifications in ISSC3 <i>Guideline for Managing Vegetation Near Power Lines</i>.</li> </ul> </li> </ul>

The following is an extract of Endeavour Energy’s Company Policy 9.1.1 Bushfire Risk Management.

## 9.1.1 BUSHFIRE RISK MANAGEMENT

### 1.0 POLICY STATEMENT

The company is committed to the application of prudent asset management strategies to reduce the risk of bushfires caused by network assets and aerial consumer mains to as low as reasonably practicable (ALARP) level. The company is also committed to mitigating, the associated risk to network assets and customer supply reliability during times of bushfire whilst achieving practical safety, reliability, quality of supply, efficient investment and environmental outcomes. The company is committed to compliance with relevant acts, regulations and codes.

Accordingly the electricity network required to service the proposed development must be fit for purpose and meet the technical specifications, design, construction and commissioning standards based on Endeavour Energy's risk assessment associated with the implementation and use of the network connection / infrastructure for a bushfire prone site. In assessing bushfire risk, Endeavour Energy has traditionally focused on the likelihood of its network starting a bushfire, which is a function of the condition of the network. Risk control has focused on reducing the likelihood of fire ignition by implementing good design and maintenance practices. However the potential impact of a bushfire on its electricity infrastructure and the safety risks associated with the loss of electricity supply are also considered.

- Earthing

The construction of any building or structure (including fencing, signage, flag poles, hoardings etc.) whether temporary or permanent that is connected to or in close proximity to Endeavour Energy's electrical network is required to comply with Australian/New Zealand Standard AS/NZS 3000:2018 'Electrical installations' as updated from time to time. This Standard sets out requirements for the design, construction and verification of electrical installations, including ensuring there is adequate connection to the earth. It applies to all electrical installations including temporary builder's supply / connections.

Inadequate connection to the earth to allow a leaking / fault current to flow into the grounding system and be properly dissipated places persons, equipment connected to the network and the electricity network itself at risk from electric shock, fire and physical injury. The earthing system is usually in the form of an earth electrode consisting of earth rods or mats buried in the ground. It should be designed by a suitably qualified electrical engineer / Accredited Service Provider (ASP) following a site-specific risk assessment having regard to the potential number of people could be simultaneously exposed, ground resistivity etc.

For details of the ASP scheme please refer to the above point 'Network Capacity / Connection'.

Endeavour Energy's Substation Primary Design Section have provided the following comments:

*Endeavour Energy's 'Design certification checklist for ASP L3' the design must comply with Endeavour Energy's 'Earthing Design Instruction EDI 001 – Earthing design risk assessment' in which schools, pre-schools, day care centres are regarded as a 'special location' – please see the following extract of EDI 001.*

The representative contact scenarios for any risk event are as follows:

- e) *Special*: implies an area within close proximity to or within a premise where there is a high likelihood that shoes will not be worn and/or the risks associated with the earthing system has the potential to be exposed to a number of people simultaneously through contact with affected metalwork. Examples include schools, pre-schools, day care centres, aquatic centres, recreational swimming areas and beaches. This classification must be assessed on a case-by-case basis and may not involve a societal assessment depending on the scenario.

*The applicant should check with their ASP responsible for the network connection to the site that any existing or future padmount substations the earthing has been designed to comply with the 'special location' requirements under EDI 100.*

- Prudent Avoidance

The electricity industry has adopted a policy of prudent avoidance by doing what can be done without undue inconvenience and at modest expense to avert the possible risk to health from exposure to emissions from electricity infrastructure such as electric and magnetic fields (EMF) and noise which generally increase the higher the voltage ie. Endeavour Energy's network ranges from low voltage (normally not exceeding 1,000 volts) to high voltage (normally exceeding 1,000 volts but not exceeding 132,000 volts / 132 kV).

In practical terms this means that when designing new transmission and distribution facilities, consideration is given to reducing exposure and increasing separation distances to more sensitive uses such as residential or schools, pre-schools, day care centres or where potentially a greater number of people are regularly exposed for extended periods of time.

These emissions are usually not an issue but with Council's permitting or encouraging development with higher density, reduced setbacks and increased building heights, but as the electricity network operates 24/7/365 (all day, every day of the year), the level of exposure can increase.

Endeavour Energy believes that irrespective of the zoning or land use, applicants (and Council) should also adopt a policy of prudent avoidance by the siting of more sensitive uses eg. the office component of an industrial building, away from and less susceptible uses such as garages, non-habitable or rooms not regularly occupied eg. storage areas in a commercial building, towards any electricity infrastructure – including any possible future electricity infrastructure required to facilitate the proposed development.

Where development is proposed near electricity infrastructure, Endeavour Energy is not responsible for any amelioration measures for such emissions that may impact on the nearby proposed development.

Please find attached a copy of Energy Networks Association's 'Electric & Magnetic Fields – What We Know' which can also be accessed via their website at <https://www.energynetworks.com.au/electric-and-magnetic-fields> and provides the following advice:

*Electric fields are strongest closest to their source, and their strength diminishes rapidly as we move away from the source.*

*The level of a magnetic field depends on the amount of the current (measured in amps), and decreases rapidly once we move away from the source.*

Typical magnetic field measurements associated with Endeavour Energy's activities and assets given the required easement widths, safety clearances etc. and having a maximum voltage of 132,000 volt / 132 kV, will with the observance of these separation distances not exceed the recommended magnetic field public exposure limits.

Endeavour Energy's Network Environment Assessment Section has provided the following advice:

*As far as Network Environment Assessment Section is aware there are no restrictions in legislation that stop schools, pre-schools, day care centres being placed next to electricity infrastructure.*

*In regard to the NSW Planning & Environment 'Child Care Planning Guideline' August 2017, besides Part 3.6 'Noise and air pollution' referring to substations as a 'noisy environment', there is no specific requirement under the site selection and location criteria to consider proximity to electricity infrastructure, although arguably a child care centre and electricity infrastructure are not a compatible use.*

*Prudent avoidance measures must however be implemented. Prudent avoidance was a policy recommended by former Chief Justice of the High Court of Australia, Sir Harry Gibbs, as a result of an inquiry he conducted into community needs and high voltage transmission lines including issues in relation to EMF back in 1991. The findings in the Gibbs report are consistent with subsequent inquiries and are still relevant today.*

*Prudent avoidance is defined as doing what can be done without undue inconvenience and at modest expense to avert the possible risk to health from exposure to new high voltage transmission facilities. In practical terms, this means designing new transmission and distribution facilities having regard to their capacity to produce EMFs, and siting them having regard to the proximity of houses, schools and the like.*

*Although the Gibbs report was particularly aimed at electricity distributors to consider when placing their infrastructure, and bearing in mind that there are schools, pre-schools, day care centres adjacent to our infrastructure in various locations right across our franchise area, it is nonetheless Endeavour Energy's recommendation that such 'sensitive uses' not be built adjacent to major electricity infrastructure.*

*Should such a development proceed, the design of the schools, pre-schools, day care centres should also consider prudent avoidance measures such as any rooms which the children will occupy (class rooms, play areas, sleeping rooms, eating areas) be arranged such that they are on the side of the site/building which is furthest away from the electricity infrastructure.*

*There is scientific consensus that health effects have not been established but that the possibility cannot be ruled out. Accordingly, if there are any concerns regarding the location of the schools, pre-schools, day care centres in proximity to the electricity infrastructure, in order to make an informed conclusion, the applicant may need to commission an independent review to provide an overall assessment including electric and magnetic field measurement and advice. Applying a precautionary approach early on in the design process will hopefully result in the adoption of prudent avoidance principles benefitting the eventual development of the site.*

Although not part of Endeavour Energy's electricity network, the applicant should consider wiring the new building and locating high electricity consuming devices away from areas occupied by children.

As part of the further noise impact assessment of the mechanical plant consideration should also be provided to the padmount substation required to facilitate the proposed development. The transformers in substations may emit a hum – especially when under heavy load say in the summer peak when use of air conditioning is at its highest. The noise is usually not perceptible enough to be regarded as disruptive and/or to the point where amelioration measures are required. As noise levels, frequency and timing can vary and people perceive sounds differently, to minimise any potential exposure to intrusive noise, the siting towards the electricity infrastructure of less sensitive uses or parts of the building not regularly occupied is recommended.

- **Vegetation Management**

The planting of large trees in the vicinity of electricity infrastructure is not supported by Endeavour Energy. Suitable planting needs to be undertaken in proximity of electricity infrastructure (including any new electricity infrastructure required to facilitate the proposed development). Larger trees should be planted well away from electricity infrastructure and even with underground cables, be installed with a root barrier around the root ball of the plant.

Landscaping that interferes with electricity infrastructure could become a potential safety risk, restrict access, reduce light levels from streetlights or result in the interruption of supply may become subject to Endeavour Energy's Vegetation Management program and/or the provisions of the *Electricity Supply Act 1995* (NSW) Section 48 'Interference with electricity works by trees' by which under certain circumstances the cost of carrying out such work may be recovered.

- **Dial Before You Dig**

Before commencing any underground activity, the applicant is required to obtain advice from the ***Dial Before You Dig 1100*** service in accordance with the requirements of the *Electricity Supply Act 1995* (NSW) and associated Regulations. This should be obtained by the applicant not only to identify the location of any underground electrical and other utility infrastructure across the site, but also to identify them as a hazard and to properly assess the risk.

- **Site Remediation**

Endeavour Energy has noted that the Environmental Site Assessment dated 21 May 2021 does not appear to identify the electricity infrastructure on or in vicinity of the site which is likely to become redundant assets as a result of the proposed development as potential areas of environmental concern (AEC) and associated contaminants of potential concern (COPC) - although in this instance it appears the overhead power lines and poles within the easement have already been removed although the following extract of the photographs in the EIS taken by City Plan during a site visit on 16 April 2021 still show the overhead power lines traversing the site.



*Figure 21: View of the site at the north-west corner, looking north-east (Source: City Plan)*

Endeavour Energy's Environmental Business Partner Team have advised that the remediation of soils or surfaces impacted by various forms of electricity infrastructure is not uncommon but is usually not significant eg. transformer oil associated with leaking substations, pole treatment chemicals at the base of timber poles etc. The method of remediation is generally the removal of the electricity infrastructure, removal of any stained surfaces or excavation of any contaminated soils and their disposal at a licensed land fill. The decommissioning and removal of the redundant electricity infrastructure will be dealt with by Endeavour Energy's Network Connections Branch as part of the application for the connection of load for the new development – please refer to the above point 'Network Capacity / Connection'.

If the applicant has any concerns over the remediation works related to redundant electricity infrastructure they should contact Environmental Business Partner Team via Head Office enquiries on business days from 9am - 4:30pm on telephone: 133 718 or (02) 9853 6666.

- Public Safety

Workers involved in work near electricity infrastructure run the risk of receiving an electric shock and causing substantial damage to plant and equipment. Please find attached copies of Endeavour Energy's public safety training resources, which were developed to help general public / workers to understand why you may be at risk and what you can do to work safely. The public safety training resources are also available via Endeavour Energy's website via the following link:

<http://www.endeavourenergy.com.au/wps/wcm/connect/ee/nsw/nsw+homepage/communitynav/safety/safety+brochures> .

If the applicant has any concerns over the proposed works in proximity of the Endeavour Energy's electricity infrastructure to the road verge / roadway, as part of a public safety initiative Endeavour Energy has set up an email account that is accessible by a range of stakeholders across the company in order to provide more effective lines of communication with the general public who may be undertaking construction activities in proximity of electricity infrastructure such as builders, construction industry workers etc. The email address is [Construction.Works@endeavourenergy.com.au](mailto:Construction.Works@endeavourenergy.com.au) .

- Emergency Contact

In case of an emergency relating to Endeavour Energy's electrical network, the applicant should note the Emergencies Telephone is 131 003 which can be contacted 24 hours / 7 days. Endeavour Energy's contact details should be included in any relevant risk and safety management plan.

I appreciate not all the foregoing issues may be directly or immediately relevant or significant to the Development Application. However, Endeavour Energy's preference is to alert proponents / applicants (and the Department) of the potential matters that may arise should development within closer proximity of the existing and/or required electricity infrastructure needed to facilitate the proposed development on or in the vicinity of the site occur.

Could you please pass on a copy of this submission and the attached resources to the applicant? Should you wish to discuss this matter, or have any questions, please do not hesitate to contact me or the contacts identified above in relation to the various matters. Due to the high number of development application / planning proposal notifications submitted to Endeavour Energy, to ensure a response contact by email to [property.development@endeavourenergy.com.au](mailto:property.development@endeavourenergy.com.au) is preferred.

With the current easing of the COVID-19 health risk, whilst a significant number of Endeavour Energy staff are returning to the office, they are at times still working from home. Although working from home, access to emails and other internal stakeholders can still be somewhat limited. As a result it may sometimes take longer than usual to respond to enquiries. Thank you for your ongoing understanding during this time.

Yours faithfully

Cornelis Duba

Development Application Specialist

Network Environment & Assessment


M: 0455 250 981

E: [cornelis.duba@endeavourenergy.com.au](mailto:cornelis.duba@endeavourenergy.com.au)

51 Huntingwood Drive, Huntingwood NSW 2148

[www.endeavourenergy.com.au](http://www.endeavourenergy.com.au)









The overhead power lines within the easement have been removed and arrangements for the release of easement are in place.

**From:** Andrew Watson <[Andrew.Watson@planning.nsw.gov.au](mailto:Andrew.Watson@planning.nsw.gov.au)>  
**Sent:** Thursday, 17 June 2021 2:30 PM  
**To:** Property Development <[Property.Development@endeavourenergy.com.au](mailto:Property.Development@endeavourenergy.com.au)>  
**Cc:** Michelle Niles <[Michelle.Niles@planning.nsw.gov.au](mailto:Michelle.Niles@planning.nsw.gov.au)>  
**Subject:** Notice of Exhibition - New Primary School at Edmondson Park (SSD-10224)



Planning,  
Industry &  
Environment

Attention: Mr Cornelis Duba  
Development Application Specialist  
Endeavour Energy

-via email-  
[property.development@endeavourenergy.com.au](mailto:property.development@endeavourenergy.com.au)

Dear Mr Duba

The Department of Planning, Industry and Environment has received an Environmental Impact Statement (EIS) for the New Primary School at Edmondson Park (SSD-10224).

The Department invites you to advise on the proposal, including advice on recommended conditions by **Wednesday 14 July 2021**. The EIS will be publicly exhibited from Wednesday 23 June 2021 until Tuesday 20 July 2021, however the Department would appreciate your advice by **Wednesday 14 July 2021** (28 days from today).

The EIS and all relevant documents may be viewed on the Department's website at: <https://www.planningportal.nsw.gov.au/major-projects/project/10181> from **Wednesday 23 June 2021**. If you would like to view the documents before this date, please use the following link to access the files [https://environmentnswgov-my.sharepoint.com/:f:/g/personal/andrew\\_watson\\_planning\\_nsw\\_gov\\_au/Eoj\\_tmwPwdxPvw7uCRTFR8MBagTMjt6c8PKQ0Y1g-TvrDA?e=K1xC5b](https://environmentnswgov-my.sharepoint.com/:f:/g/personal/andrew_watson_planning_nsw_gov_au/Eoj_tmwPwdxPvw7uCRTFR8MBagTMjt6c8PKQ0Y1g-TvrDA?e=K1xC5b).

If you have any questions, please contact Michelle Niles on (02) 9274 6272 or via email at [michelle.niles@planning.nsw.gov.au](mailto:michelle.niles@planning.nsw.gov.au).

Kind regards

**Andrew Watson**  
**DA Coordinator**

Key Sites & Regional Assessments | Department of Planning, Industry and Environment  
T 02 8275 1645 | E [Andrew.Watson@planning.nsw.gov.au](mailto:Andrew.Watson@planning.nsw.gov.au)  
Level 17, 4 Parramatta Square, 12 Darcy Street | Locked Bag 5022 | Parramatta NSW 2150  
[www.dpie.nsw.gov.au](http://www.dpie.nsw.gov.au)



Planning,  
Industry &  
Environment

**Our Vision:** Together, we create thriving environments, communities and economies.

*The Department of Planning, Industry and Environment acknowledges that it stands on Aboriginal land. We acknowledge the traditional custodians of the land and we show our respect for elders past, present and emerging through thoughtful and collaborative approaches to our work, seeking to demonstrate our ongoing commitment to providing places in which Aboriginal people are included socially, culturally and economically.*