

The Secretary
NSW Department of Planning, Industry & Environment

5 May 2022

ATTENTION: Lucinda Craig

Dear Sir or Madam

I refer to the Department's email of 4 May 2022 regarding the exhibition of the Environmental Impact Statement (EIS) for State Significant Development SSD-24452965 Eels Centre of Excellence & Community Sports Hub for 'Construction of Parramatta Eels Centre of Excellence, including high-performance training centre and ancillary uses, new recreation and community sports hub, new 1,500 seat grandstand and spectator mounding, and additional car parking' at 8 Memorial Avenue, Kellyville (Lot 60 DP10702, Lot 1 DP167535) in The Hills Shire Local Government Area (LGA). Submissions need to be made to the Department by 31 May 2022.

In regard to Endeavour Energy's submission made to the Department via email on 4 August 2021 to the request for Secretary's Environmental Assessment Requirements (SEARs), the recommendations and comments provided therein essentially remain valid.

Endeavour Energy has noted the following advice is provided in the Infrastructure Management Report.

6.3 Proposed Services

6.3.1 Electrical Distributor Infrastructure

Based on the development masterplan, the Electrical infrastructure will be upgraded.

Kiosk Requirements

Existing kiosk located along Stone Mason Drive to be upgraded. Refer to Level 3 ASP consultant authority upgrade design work drawings for detail, once made available in latter design phases. New development requires a total demand of ~760 amps per phase three phase. * refer to PTC connection offer letter received Feb 2022.

Cabling infrastructure

New inground main consumer cabling from the kiosk to the MSB to be installed.

The Permission to Connect (PTC) / connection offer letter is not included in the Infrastructure Management Report.

For matters related to the electricity supply the applicant and their Accredited Service Provider (ASP) will need to continue to engage with Endeavour Energy's Customer Network Solutions Branch [via Head Office enquiries on business days from 9am - 4:30pm on telephone: 133 718 or (02) 9853 6666] who are responsible for managing the conditions of supply with the proponent and their Accredited Service Provider (ASP).

For matters related to easement management or protected works / assets enquiries (other than those related to works approved / certified by Endeavour Energy's Customer Network Solutions Branch as part of an enquiry / application for load or asset relocation project), enquiries should be directed to Endeavour Energy's Easements Officers via Head Office enquiries on business days from 9am - 4:30pm on telephone: 133 718 or (02) 9853 6666 or alternatively by email Easements@endeavourenergy.com.au.

Endeavour Energy has no further recommendations or comments regarding the EIS.

Could you please pass on a copy of this submission to the applicant? Should you wish to discuss this matter, or have any questions, please do not hesitate to contact me or the contacts identified above or in Endeavour Energy's previous submissions in relation to the various matters. Due to the high number of development application / planning proposal notifications submitted to Endeavour Energy, to ensure a response contact by email to property.development@endeavourenergy.com.au is preferred.

Yours faithfully

Cornelis Duba

Development Application Specialist

Sustainability & Environment

M: 0455 250 981

E: cornelis.duba@endeavourenergy.com.au

51 Huntingwood Drive, Huntingwood NSW 2148

www.endeavourenergy.com.au

